



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 33 M	OLR ACTED	RESET	02:00:00	02:15:00	
2	CHP	SCR 7 ON CC 34	SLEW RETURN FILTER FULL INDICATION NOT COMING	BY PASSED AS PER MECH REQUEST	23:30:00	23:50:00	
3	CHP	SCR 3 ON CC 37 LT	DRIVE TRIPPED	RESET	00:20:00	00:30:00	
4	CHP	S3 ON CC 33 SLEW	30 DEGREE RIGHT LIMIT SWITCH PROBLEM	BYPASSED	05:00:00	05:15:00	
5	WT	OP10	OVER TRAVELED AND HIT OT5 DUE TO WAGON LOAD GRAVITY WHILE OVERSHOOTING OF WAGONS	MAJOR DAMAGE OCCURRED	04:15:00	06:00:00	
6	IOSA	BRC ON OC 18A LT	M3 TRIPPED	RESET	00:20:00	00:35:00	