



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 27/06/2025

Area: OHP

Equipment	Job
co-11,12,13,rsco-10a	receiving chute vibrators status is checked, rsco-10a chute vibrator mother plate is damaged, needs to be replaced.
co-10,13,16	motor and panel side ppm is done
tt-1 on co-21	position sensor is replaced and tested.
transfer car	pcrd layering is done properly
1-14lc4	water levels checked and de watering is done.
tbs-4 on co-5a	drives and safety devices ppm is done
brc-1	shifted from co-8a to co-28
brc-3	shifted from co-28 to co-8a
locp-2	crusher area illumination is improved.
co-45 burnt motor	coupling is removed and kept at lc7
CR-1	GE vacuum contactor coil burnt, replaced with spare one and adjusted auxiliary contacts properly and trail run taken.