



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|-----------------------------------------------------------------------|-------------------------------------|----------------------------------|----------------------------------|----------|
| 1 | OHP | CO 12 CD | OLR ACTED | RESET | 12:45:00 | 12:55:00 | |
| 2 | OHP | BRC ON CO 31 | B/C OLR ACTED | RESET | 06:20:00 12:50:00 | 06:35:00 13:00:00 | |
| 3 | OHP | CO 29 | OLR ACTED | RESET | 07:20:00 09:05:00 11:40:00 | 07:25:00 09:10:00 11:45:00 | |
| 4 | OHP | CO 26 | OLR ACTED | RESET | 09:15:00 14:00:00 | 09:20:00 14:05:00 | |
| 5 | CHP | CC 51 | FEEDING MPD TRIPPED | RESET | 11:00:00 | 13:30:00 | 6 TIMES |
| 6 | CHP | CC 51 | OLR ACTED | RESET | 12:40:00 | 12:45:00 | |
| 7 | CHP | CC 54 | OLR ACTED | RESET | 07:00:00 | 13:40:00 | 15 TIMES |
| 8 | CHP | CC 131 | OLR ACTED | RESET | 07:30:00 09:20:00 10:50:00 | 07:35:00 09:25:00 10:55:00 | 3 TIMES |
| 9 | CHP | CC 51 TIS | OLR ACTED | RESET | 06:05:00 | 06:10:00 | |
| 10 | CHP | SCR 3 ON CC 35 | B/C TRIPPED ON SP FAULT | RESET | 10:10:00 | 10:20:00 | |
| 11 | CHP | SCR 2 ON CC 34 | LUFF POWER WAS IN OFF CONDITION | MADE IT ON | 11:20:00 | 11:30:00 | |
| 12 | CHP | SCR 2 ON CC 34 | B/C STOPPING FREQUENTLY DUE TO YARD RUNNING SIGNAL MISSING TO MACHINE | FEED TABLE ZSS CAGE KEPT IN CIRCUIT | 12:15:00 | 12:30:00 | |
| 13 | CHP | CC 45 | OLR ACTED | RESET | 11:05:00 11:20:00 | 11:10:00 11:25:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------------------------|----------------|---------|----------|----------|---------|
| 14 | CHP | CC 28 | OLR ACTED | RESET | 13:00:00 | 13:10:00 | |
| 15 | WT | A4 (OT2) TRIPPING FREQUENT LY | DRIVE REPLACED | THEN OK | 06:00:00 | 09:00:00 | |