



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/08/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO7	BRS bypassed was removed on operational request	Kept in ckt	06:15:00	06:15:00	
2	OHP	RSCO10A carriage	MPCB Tripped	Reset done	12:00:00	12:10:00	
3	OHP	CO19	BRS not getting reset found trans and receiver alignment problem	Reset done	13:27:00	13:45:00	
4	OHP	CO25	olr acted	Reset done	11:00:00	11:10:00	
5	OHP	CC125	OLR tripped 2 times	Reset done	08:20:00	08:25:00	01.20am to 01.25am
6	CHP	CC51	Tripped and feeding conveyor stopped 4 times	Reset done	06:40:00	06:45:00	08.30am to 08.35am : 09.50am to 09.55am:01.05pm to 01.10pm
7	CHP	CC54	Olr tripped due to over load	Reset done	12:55:00	13:00:00	
8	CHP	CC33	BRS bypassed as per operational request	bypassed	12:30:00	12:40:00	
9	CHP	SCR4 on CC33	LT not working found VFD drive tripped (SCF-3)	Reset done then ok	13:15:00	13:25:00	
10	CHP	CC47	Not started	Power recycling done	07:15:00	07:18:00	
11	WT	OT2	Drive 1 tripped on PGF fault	Reset done	08:30:00	08:35:00	
12	WT	OT4	Drive1 tripped on PGF fault	reset done	10:00:00	10:05:00	