



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/11/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	CT END LIMIT SWITCH REPLACED AND ACTUATOR ADJUSTMENT DONE. CJB and PJB PANELS ARE PROPERLY FIXED. TIGHTNESS CHECKED IN CJB AND PJB.
OC-7A and 7B	LIGHTING AND SWITCH BOARD CONNECTIONS GIVEN FOR BELT JOB
OC-14A	PPM DONE ON MOTOR
OC-13A	PPM DONE ON FIELD DEVICES