



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 06/08/2025

Area: OHP

| Equipment                        | Job  |
|----------------------------------|--|
| TT NEW MODEMS                    | POWER UP AND TESTING UNDER PROGRESS            |
| CC 29                            | MOTOR VIBRATION READING TAKEN                  |
| CC 109                           | 120W LIGHT FIXER DONE                          |
| CC 9                             | 200 W FIXER GIVEN                              |
| CF1                              | CHUTE SENSOR RECTIFIED                         |
| JH2                              | LIGHTING RESTORED AND 1 200 W FIXED            |
| CO 5, 8 9, 10, 15, 16            | VIBRATION CHECKING DONE AND GREASING ALSO DONE |
| CO 4A                            | MOTOR AND PANEL SIDE PPM DONE                  |
| JH14                             | SPARE MOTORS BLOWING DONE                      |
| 37 KW MOTOR                      | SHIFTED TO 30A HEAD END                        |
| CO 59, 62B ELT AND CARRIER DRIVE | MOTOR and panel ppm done                       |