



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	bc not running,CS acted	reset	09:38:00	09:45:00	
2	OHP	co 29	olr acted	reset	06:50:00	06:55:00	
3	OHP	co 29	olr acted	olr acted	12:50:00	13:00:00	
4	OHP	co 84	olr acted	reset	13:50:00	14:00:00	
5	OHP	OP 7	no reverse movement,rev lt acted	rev limit released	09:00:00	09:10:00	
6	CHP	CC 114	olr acted	reset	09:40:00	09:45:00	
7	CHP	BRC on co 30	b/c not running,Cs acted	reset	11:45:00	11:59:00	
8	CHP	CC 45	olr acted	reset	09:00:00	09:05:00	2 times
9	CHP	CC 34 SCR2	slew not working,jamming	informed operation	10:55:00	11:05:00	
10	CHP	CC 112 SCR 8	Lt not working,PCRD gear box damaged	informed mech	10:40:00	10:50:00	
11	CHP	CC 28 flap gate	mpcb trips	made it on	13:25:00	13:35:00	
12	WT	CP 4	communication problem	power recycled	07:00:00	07:05:00	
13	WT	co 3	olr acted	reset	09:15:00	09:25:00	
14	WT	OP 9	not moving,rake is in decoupled	informed operation	12:15:00	12:30:00	