



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/12/2025

Area: WT

Equipment	Job
OP 1	D 4 motor slip rings buffing and cleaning done and brush holder repaired
OP 1	D 4 motor, fixed the brush holder and replaced all brushes, kept in circuit
OP 6 and CP 1	After rake, maintenance done