



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 16/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO-25	YARD TO BC ZSS INTERLOCK CAGE STUCK	MADE FREE	03:50:00	04:10:00	
2	OHP	CO-31 BRC	BC NOT RUNNING ... INTERLOCK ZSS CAGE HIGH LOOSE	FIXED AND TESTED	01:45:00	02:00:00	
3	OHP	CO-16	STOPPING ON ZSS... PROB WIRE CUT NEAR NECK	PROB CHANGED AND TESTED	01:00:00	01:20:00	
4	OHP	WBR ON CO-6A	BC OLR ACTED	RESET DONE	23:15:00	23:25:00	
5	OHP	CO-28	TRIPPED ON OLR	RESET DONE	03:40:00	03:50:00	
6	OHP	BPC-2	BSS ACTED DUE TO OFF CENTERING	BSS BYPASSED IN CJB	03:30:00	03:40:00	
7	CHP	CC-35 SCR-3	BC TRIPPED ON OLR	RESET DONE	02:15:00	02:30:00	
8	CHP	CC-29	TRIPPED DUE TO OVER LOAD	RESET DONE	01:45:00 02:35:00 04:10:00	01:50:00 02:40:00 04:15:00	
9	CHP	CC-54	TRIPPED 3 TIMES	RESET DONE	05:10:00	05:35:00	
10	WT	AF-4	DRIVE TRIPPED	RESET DONE	23:00:00	23:05:00	
11	WT	OT-5	DRIVES TRIPPING DUE TO ROLLER JAMMING	RESET AND INFORMED OPERATION FOR CLEANING	23:30:00	00:00:00	