



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-84	TRIPPED ON OLR	RESET DONE	02:25:00 03:45:00	02:35:00 04:05:00	
2	OHP	CO-20	BRS NOT RESETTING	WIRES TIGHTEN IN TB THEN OK	22:30:00	22:50:00	
3	OHP	CO-34 BRC	BC OLR ACTED	RESET DONE	00:45:00	01:00:00	
4	OHP	CO-67	OLR ACTED	RESET DONE	00:50:00 02:35:00	01:05:00 02:50:00	
5	OHP	CO-84	OLR ACTED	RESET DONE	03:25:00	03:35:00	
6	OHP	CO-28 BRC	BC NOT RUNNING EM PUSH BUTTON ACTED NEAR CABIN	RELEASE	03:45:00	04:05:00	
7	OHP	CO-25	TRIPPED ON OLR	RESET DONE	04:20:00	04:30:00	
8	OHP	CO-34 BRC	YARD INTERLOCK ZSS CAGE STONE STUCK	MADE FREE	04:35:00	04:55:00	
9	CHP	CC-51	MPD TRIPPED 7 TIMES (FEEDING CONVEYOR STOPPED)	RESET DONE	23:20:00	03:50:00	
10	CHP	CC-51	OLR ACTED	RESET DONE	02:05:00 02:20:00	02:10:00 02:25:00	
11	CHP	CC-131	TRIPPED ON OLR	RESET DONE	04:35:00	04:40:00	
12	CHP	CC-40 SCR-3	BC NOT RUNNING	CHUT JAM .. INFORMED FOR CLEANING	01:00:00	01:10:00	
13	CHP	CC-40 SCR-3	LT NOT WORKING DRIVE TRIPPED	RESET DONE	02:10:00	02:20:00	
14	CHP	CC-31 SCR-4	LT NOT WORKING PCRD OVER TENSION ACTED	RELEASED	03:05:00	03:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/09/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-50	FREQUENTLY STOPPING	CHUT SENSOR WIRE LOOSE IN CJB FIXED PROPERLY	04:30:00	05:00:00	
16	CHP	CC-26A	TRIPPED ON OLR	RESET DONE	05:20:00	05:30:00	
17	WT	OT-3	DRIVE TRIPPED ON ENCODER FAULT	RESET DONE	03:20:00	03:25:00	