



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 33M	tripped on olr	reset done	07:20:00	07:30:00	
2	OHP	brc on co 33m	bc not running/olr acted due to jamming	reset done	11:00:00	11:30:00	
3	OHP	tbs on co 23	lbc zss acting/module defective	zss module replaced then ok	11:00:00	11:30:00	
4	OHP	co 30	brs acting /belt pieces hanging	inform to operation	12:10:00	12:25:00	