



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/12/2025

Area: CHP

| Equipment                                    | Job                                                         |
|----------------------------------------------|-------------------------------------------------------------|
| JH C 8,9,10                                  | 4 nos 120W fixtures provided                                |
| CC<br>32,34,42,44,45,46,48,49,105,SCR1,10,R1 | Running inspection was done                                 |
| CC 222/223                                   | One 120W LED provided, 5 nos 70W fixtures mad ready for use |
| SCR 8                                        | PCRD OT cam adjusted and kept in ckt                        |
| LC 5                                         | Room cleaning under progress                                |
| CC 28,28TT,109,36,41,S 1,CC 55               | PPM was done                                                |