



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 28/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-25	Reported yard ZSS problem	Cage stuck up.Replaced and tested okay	14:30:00	14:45:00	
2	OHP	CO-6A	ZSS probe damaged	Probe replaced and tested okay	15:50:00	16:05:00	
3	OHP	BRC on CO-8A	Reported B/C not running	ACB tripped.Made on and tested okay	18:20:00	18:35:00	
4	OHP	CO-29	Reported tripped	OLR acted.Reset done	18:30:00	18:35:00	
5	OHP	WOBR on CO-25	Reported interlock ZSS problem	Cage stuck up.Made free and tested okay	19:47:00	20:04:00	
6	OHP	WOBR on CO-6A	Reported luffing not taking place	Wrong complaint	19:25:00	19:40:00	
7	OHP	Cc-51	Reported tripped.	MPD tripped.reset done(10 times).	15:00:00	21:00:00	
8	OHP	CO-19,20,21,22	Reported all conveyors not healthy	fuse burnt in LC-7 common high to BRS.Fuse replaced and tested okay	21:10:00	21:32:00	
9	CHP	CC-54	Reported tripped	OLR acted.Reset done(7times)	14:45:00	19:00:00	
10	CHP	CC 105	D/E chute sensor not healthy	Wrong complaint	17:20:00	17:30:00	
11	CHP	Cc-39 SCR-2	Reported Lt not working	PCRD OT acted.Released and tested okay(3 times)	17:40:00	20:10:00	
12	CHP	Cc-33 SCR-5	LT not working	PCRD OT acted.Released and tested okay	20:50:00	21:10:00	
13	CHP	CC-35 SCR-3	Reported B/C not running	OLR acted.Reset done	21:30:00	21:40:00	