



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 10 A	olr acted	reset	01:10:00	01:25:00	
2	OHP	RSCo 10 A	olr acted	reset	03:30:00	03:40:00	
3	OHP	TBS on CO 19	left boom fallen,push button up down interchanged	interchanged PB	05:35:00	05:50:00	
4	CHP	CC 35 SCR3	b/c not running,olr acted	reset	23:30:00	23:40:00	
5	CHP	CC 216	olr acted	reset	04:10:00	04:20:00	
6	CHP	CC 112 SCR8	b/w not running ,oil level low	informed mechanical	04:30:00	04:45:00	
7	CHP	CC 58	mpd tripped	reset	01:30:00	01:45:00	
8	CHP	CC 31 SCR4	b/w not running,	control desk to PLC communication problem	05:50:00	06:30:00	pending
9	WT	oc1A,oaf1A, oaf2A	red	PLC r/io power recycle done	22:00:00	22:10:00	
10	IOSA	ALL conveyor	red,communication problem	pending	02:00:00	06:30:00	