



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/05/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR ACTED	RESET	09:00:00	09:10:00	
2	OHP	TBS ON 23	PCRD GUIDE DAMAGED AND CHAIN BROKEN	INFORMED TO MECH	08:45:00	09:00:00	
3	OHP	TBS ON CO 19	LEFT LUFF NOT TAKING PLACE OLR ACTED DUE TO BRAKE PROBLEM	RESET	10:00:00	11:00:00	INFORMED TO MECHANICAL NO ELECTRICAL PROBLEM
4	OHP	CO-23	BRS NOT RESET	GLASS RELAY AND SENDER SENSOR REPLACED THAN OK	12:30:00	13:00:00	
5	CHP	CC131	OLR ACTED	RESET	12:55:00	13:00:00	
6	CHP	CC 104 SCR 9	TUL C/S NOT WORKING MODULE PROBLEM	MODULE CHANGED	10:00:00	10:15:00	
7	CHP	CC-35 SCR-2	LT NOT TAKING PLACE O/T LIMIT ACTED	RELEASED	12:45:00	13:00:00	
8	WT	OP 5	DRIVE 1 TRIPPED COUPLING TIME	RESET	10:20:00	10:30:00	