



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/06/2025

Area: WT

Equipment	Job
MIS	shift room building lighting circuit problem,rectified
CO 4 level	lighting complaint ,rectified 200W LED provided
LC 9	All Drive panels and LDBs blowing and floor cleaning done
OP 10	panel and motor side ppm done
OP 10	glass window found broken, GI plate welding done
OP1 and 3	after rake maintenance done