



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/02/2026

Shift: B

Incharge(s): Amit Roy

| Sl No | Area | Equipment      | Problem                  | Action  | From     | To       | Remarks |
|-------|------|----------------|--------------------------|---|----------|----------|---------|
| 1     | OHP  | CO-15          | ZSS acting               | Cage bearing problem.Replaced and tested okay                   | 16:36:00 | 17:00:00 |         |
| 2     | OHP  | VS-2           | Reported tripped         | OLR acted.Reset done  | 19:15:00 | 19:20:00 |         |
| 3     | CHP  | CC-54          | Reported tripped         | OLR acted.Reset done(5 times)                                   | 14:40:00 | 20:00:00 |         |
| 4     | CHP  | CC-51          | MPD tripped              | Reset done  | 20:20:00 | 20:25:00 |         |
| 5     | CHP  | CC-203         | Reported tripped         | OLR acted.Reset done  | 14:20:00 | 14:30:00 |         |
| 6     | CHP  | CC-32<br>SCR-5 | Lt not taking place      | M4 tripped.Reset done   | 14:50:00 | 15:00:00 |         |
| 7     | CHP  | CC-31<br>SCR-4 | LT not taking place      | PCRD tension acted.Released and tested okay                     | 14:55:00 | 15:05:00 |         |
| 8     | CHP  | CC-40<br>SCR-2 | Slew not taking place    | wrong complaint   | 18:50:00 | 18:55:00 |         |
| 9     | CHP  | Cc-216         | Reported tripped         | OLR acted.Reset done  | 20:00:00 | 20:05:00 |         |
| 10    | CHP  | CC-7           | Reported C/S not healthy | High found loose at CJB.tightened and tested okay               | 16:11:00 | 16:25:00 |         |
| 11    | CHP  | CC-14          | Reported not healthy     | OLR acted.Reset done  | 16:20:00 | 16:25:00 |         |
| 12    | CHP  | Cc-28          | Reported tripped         | OLR acted.Reset done(2 times)                                   | 14:00:00 | 16:45:00 |         |
| 13    | WT   | OP-5           | Reported not moving      | Pusher found at dead end.Jumpers laid and pusher moved forward. | 21:10:00 | 21:40:00 |         |