



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/09/2025

Area: CHP

| Equipment | Job |
|-----------------|---|
| RG building | All LT motors greasing done and screen area lighting improved |
| CC 51,51A | PPM was done |
| CC 39 S1 | PCRD cable layering was done |
| CC 201`/222/223 | Belt scale units maintenance was done |
| CC 42 | BRS kept in ckt |
| CC 49/50 | Staircase area 2nos lamp fixtures rectified |
| CC 222/223 | Defective lamp fixtures removed and brought for rectification |
| CC 43/44 | 3 nos 50W LED lamps replaced |
| CM 18 | Cleaning under progress |
| STACKER 3 | HT cable damaged joint wrapper was replaced by DNW |