



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/02/2026

Area: WT

Equipment	Job
OP 10	Antenna pipe and Antenna fixed ,Ethernet cable checked and connected
OP 10	All drives checked and moved in LOCAL
OP 10	Trolly line inspection done
OP 10	After col no78 Mast is touching to Trolly line,brought to maintenance zone
OP 3	D3 Motor removed for gear box repair job
OP 3	After rake maintenance done