



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-58(B)	MPCB TRIPPED	RESET DONE	03:50:00	04:00:00	
2	OHP	BRC ON CO-32	REPORTED PUMP NOT RUNNING CHECKED AND FOUND 24V GLASS FUSE BLOWN DUE TO EARTH FAULT CHERRY MATERIAL AND RAIN WATER ENTER IN CJB	CJB CLEANING AND EARTH FAULT ISOLATED THAN GLASS FUSE REPLACED THAN OK	03:50:00	04:50:00	
3	CHP	CC-28 TT	POSITION INDICATION ON CC-33 NOT SHOWING GLASS FUSE BLOWN IN I/O RACK	GLASS FUSE REPLACED	01:50:00	02:00:00	
4	CHP	CC-54	TRIPPED ON OLR (5TIMES)	RESET DONE	00:45:00	05:15:00	
5	CHP	CC-112 SCR-8	REPORTED SLEW L-SIDE NOT WORKING FOUND STAKING TIME 30DEGRE LIMIT ACTED	INFORM TO OPERATION	23:10:00	23:20:00	
6	CHP	CC-31	REPORTED STOPPING ON ZSS FOUND BELT SLIP	INFORMED TO MECHANICAL	00:40:00	01:00:00	
7	CHP	CC-104 SCR-9	LT NOT TAKING PLACE PCRD O/T ACTED AND MOTOR-7 AND 8 TRIP DUE TO TRACK JAMMING	PCRD O/T RELEASED M-7 ,M-8 RESET DONE AND INFORM TO OPERATION	00:50:00	01:30:00	
8	CHP	CC-104 SCR-9	SLEW TRIPPED ON OLR	RESET DONE	02:40:00	02:50:00	
9	CHP	CC-33	FREQUENTLY STOPPING ON ZSS CHECKED AND FOUND BELT SLIP DUE TO RAIN WATER	INFORM TO OPERATION	04:30:00	04:50:00	
10	CHP	CC-105 SCR-10	LT NOT TAKING PLACE M-4 MPCB TRIP	MPCB MADE ON	04:50:00	05:00:00	DUE TO TRACK JAMMING



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	WT	OC-1A (B)	TRIPPED ON OLR	RESET DONE	22:10:00	22:25:00	
12	WT	CP-1	NOT MOVE FOUND ACB TRIP IN LC-10A	MADE ON THAN OK	23:10:00	23:30:00	
13	WT	OC-1A	REPORTED RED FOUND PULL CHORD ACTED	RESET DONE THAN OK	01:35:00	01:45:00	
14	WT	OT-2	NOT ROTATED DRIVE-1 PGF FAULT TRIP	RESET DONE	05:00:00	05:10:00	