



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/10/2025

Area: WT

Equipment	Job
OP 2	Emergency Switch replaced ( not making properly )
OP 3	Trolley line inspection done ,col no 71 to 72 bus bar middle and bottom adjusted
OP 2	D4 motor removed and shifted to tippler house,bypassed it ( 5 motors in circuit)
OP 2	Motor side ppm done, found D4 motor ,stator winding burnt
OP 2,3 and 8	after rake maintenance done