



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/05/2025

Area: WT

Equipment	Job
	4 Pole mcb replaced hopper light LDB
OP4	Pannel side and motor side ppm done
OT2	Series pannel and motor side ppm done
CP4	3 no's of isolator boxes ppm done

CT1 &2