



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 18/12/2025

Area: CHP

Equipment	Job
CC 34,40,42,SCR1	Motors greasing done
CC 41/42	Lighting 4pole MCB and aux contactor replaced and restored lighting.One welding supply point provided at JH C17
CC 34,SCR1	PPM was done
S 3	HT cable faulty core replaced with spare core with the help of DNW and charges supply after replacing fuse
LC 15 to LC 16	Profibus cable laid and terminated ,found up to CM 16 communication is healthy