



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/12/2025

Area: IOSA

Equipment	Job
WOBR-LnT	TRIAL RUN TAKEN.
WOBR-FLS	TRIAL RUN TAKEN
BRC	PPM DONE ON FIELD DEVICES.
BRC	FESTOON CABLE ADJUSTMENT DONE.
OC-13A	CONDUIT LAYED FOR OC-13A COUPLER SPACE HEATER.
OM-4	OM-4 TO OC-7C GALLERY CABLE MADE READY FOR LAYING.
BRC	LT MOTOR-4 THRUSTER BRAKE FIXED AND CHECKED.