



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS1A	OLR ACTED	RESET	07:50:00	08:00:00	
2	CHP	CC 114	OLR ACTED	RESET	08:10:00	08:15:00	
3	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	10:45:00	13:30:00	6 TIMES
4	CHP	CC 54	OLR ACTED	RESET	12:45:00	12:50:00	
5	WT	AF5	DRIVE TRIPPED	RESET	11:55:00 13:00:00	12:00:00 13:05:00	
6	WT	OP6	DRIVE 5 OLR ACTED	RESET	11:50:00	12:05:00	