



ELECTRICAL GENERAL SHIFT REPORT

Area: OHP

| Equipment | Job |
|--------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|
| co-10,13 | motor and panel side ppm is done |
| bf-1a,2a,7a,8a,9a,vs-1a,2a,3a,4a,5a,mo-14a,bt-1a,13a,side-1a | motor and panel side ppm is done |
| jh o-14,bpc-1 h/e hoists | ppm is done. jh o-14 welding machine cable proper termination done at power source. |
| co-33a,35a,37a | safety devices ppm is done. co-31a motor termination is removed as motor is shifted for mechanical job, re-termination needs to be done after their clearance. |
| co-7,10,13 | motor and panel side ppm is done |
| tbs-1 on co-22 ; tbs-7 on co-19,co-19,21,23 | motor and panel ppm is done. |
| BRC-2 on co-31 | HT transformer is changed and tested. old transformer is shifted to hvmmc-1 . |