



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	REPORTED LT NOT TAKING PLACE FOUND DRIVE TRIPPED	RESET DONE	06:30:00	06:40:00	
2	OHP	CO-29	TRIPPED ON OLR	RESET DONE	09:25:00	09:30:00	
3	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (3TIMES)	RESET DONE	07:30:00 08:00:00 12:55:00	07:35:00 08:05:00 13:00:00	
4	CHP	CC-114	OLR ACTED	RESET DONE	08:05:00	08:10:00	
5	CHP	CC-38 SCR-6	SIGNAL MISSING	LT MOVE FOR/D THAN OK	07:30:00	07:35:00	
6	CHP	CC-108	OLR ACTED	RESET DONE	08:50:00	08:55:00	
7	CHP	CC-40 SCR-2	REPORTED SLEW NOT WORKING FOUND 30 DEGREE LIMIT ACTED	RELEASED THAN OK	08:45:00	08:55:00	
8	CHP	CC-105 SCR-10	REPORTED PCRD CABLE UNEVEN	PCRD GUIDE ADJUSTED AND CABLE PROPER LAYING WAS DONE	08:55:00	09:20:00	
9	CHP	CC-203	OLR ACTED	RESET DONE	11:05:00	11:10:00	
10	CHP	CC-125	TRIPPED ON OLR	RESET DONE	12:25:00	12:30:00	
11	WT	OT-5	REPORTED FOR/REV NOT ROTATED FOUND OUT HALL SIDE E/STOP ACTED	RELEASED THAN OK	08:20:00	08:30:00	