



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/09/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	olr acted	reset it done	03:30:00	03:35:00	
2	OHP	co 26	olr acted	reset	00:25:00	00:30:00	
3	OHP	CO 49	olr acted	reset	00:20:00	00:40:00	
4	OHP	TT 3	position indication not healthy	fuse blown,fuse replaced	03:15:00	03:30:00	
5	OHP	CO 33M	olr acted	reset	04:55:00	05:00:00	
6	OHP	CO 29	olr acted	reset	05:00:00	05:15:00	
7	OHP	CO 35	OLr acted	reset	03:20:00	03:30:00	
8	OHP	TBS on CO 5A	no power,acb is in off	acb made on	05:20:00	05:30:00	
9	OHP	CO 35	Emergency PB 2 (YARD)acted	PB ok return side high also coming, cable fully jammed under material	23:00:00	23:20:00	Emergency PB 2 yard side bypass in program, to be checked in general shift
10	CHP	CC 29 on 111	bit was missing,i/o rack cable was loose connection	tightened it	00:50:00	01:05:00	
11	CHP	CC 51	mpd tripped on OL	reset	22:30:00	06:00:00	5 times
12	CHP	CC 54	motor tripped in OLR	reset	22:50:00	22:55:00	
13	CHP	CC 52	TIS motor tripped on overload due to scrap metal	reset	01:10:00	01:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/09/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 31	olr acted	reset	23:30:00	23:40:00	
15	CHP	CC 31 SCR4	LT not taking, motor mpcb tripped, track full jamming	informed operation, mpcb made on	23:45:00	23:55:00	
16	CHP	CC 33 SCR5	b/w not running, b/w stucked in coal heap	LT rev done than ok	00:10:00	00:20:00	
17	CHP	CC 37 SCR 7	LT not taking place, OT acted	OT released	02:45:00	02:55:00	
18	CHP	CC 33 SCR 5	b/w not running, low ACC pressure p2	informed mech	05:15:00	05:30:00	