



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/01/2026

Area: WT

Equipment	Job
OP 6	Section isolators maintenance done,2 nos (col no:84 and 91)
OP 5	Section Isolators maintenance done ,5nos (col no:67,72,79,87,93)
OP 2 ,3, 5 and 6	After rake maintenance done
MIS	Bed drain pumps inspection done both Tipplers and status informed to WMD
MIS	75W sample LEDs installed one @ OAF level and one @ LC 10A entrance area