



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 113	OLR ACTED	RESET	00:35:00	00:45:00	
2	CHP	cc 51	FEEDING CONV OLR ACTED	RESET	22:40:00	05:30:00	13 TIMES
3	CHP	RG3 F/G	TRIPPED	RESET	03:35:00	03:45:00	
4	CHP	STK ON CO 20 LEFT LUFF	CAM LIMIT SWITCH PROBLEM	ADJUSTMENT DONE THEN OK	00:45:00	01:45:00	