



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 22/07/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED (4 TIMES )	RESET DONE	23:15:00	01:00:00	
2	OHP	CO-29	OLR ACTED	RESET DONE	00:12:00 01:40:00	00:20:00 01:50:00	
3	OHP	CO-28 BRC	LT NOT WORKING	PCRD GUIDE PROBLEM ... INFORMED MECH	00:40:00	01:00:00	
4	OHP	CO-27A	BRS BYPASS REQ	BYPASSED	01:40:00	01:55:00	
5	OHP	CO-17TO 23 FLAP GATE	TRIPPED	RESET DONE	04:05:00	04:10:00	
6	OHP	CO-23	BRS NOT RESETTING	MODULE PROBLEM .. BYPASSED	04:20:00	04:40:00	TO BE CHECKED
7	OHP	TT-4	LT NOT WORKING	110V MCB TRIPPED ... MADE ON	23:00:00	23:15:00	
8	OHP	SCO-1A	TRIPPED ON OLR	RESET DONE	03:30:00	03:45:00	
9	CHP	CC-104 SCR-9	BC NOT WORKING	ACB TRIP... MADE ON	22:20:00	22:35:00	
10	CHP	CC-104 SCR-9	LT NOT WORKING	OVER TENSION ACTED ... RELEASED	00:00:00 00:55:00	00:20:00 01:15:00	
11	CHP	CC-51	MPD TRIPPED	RESET DONE	04:34:00	04:40:00	
12	CHP	CC-54	TRIPPED ON OLR	RESET DONE	01:35:00 02:00:00	01:40:00 02:10:00	
13	WT	OP-9	FWD NOT MOVING ... OT -5 LS-2 ACTED	LS-2 BYPASSED	03:15:00	03:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/07/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT-1	INITAL PROBLEM	LIMIT SWITCH DISC AND ACTUATOR BROKEN ... AND SPROCKET NOT ENGAGING SOME TIMES ... BECOUSE OF THAT LIMIT SETTING GETTING DISTURBED ... ..REV LIMIT SETTING DONE	23:30:00	05:30:00	FWD LIMIT TO BE SET WITH WAGON