



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 05/01/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------|----------------------------|--|----------------------|----------------------|---------|
| 1 | OHP | CO 26 | OLR ACTED | RESET | 14:30:00 | 14:40:00 | |
| 2 | OHP | CO 21 | ZSS PROBE CABLE GOT CUT | REJOINT | 15:30:00 | 15:45:00 | |
| 3 | OHP | WBR ON CO 29 | LT DOWN LIMIT ACTED | BYPASSED AND LIFTED THEN ALL DRIVES OK | 18:15:00 | 18:30:00 | |
| 4 | CHP | CC 52 | FEEDING CONVEYOR MPD ACTED | RESET | 18:05:00 | 18:10:00 | |
| 5 | CHP | CC 23 | ZSS PROBE CABLE GOT CUT | REJOINT THEN OK | 18:46:00 | 18:55:00 | |
| 6 | CHP | SCR 6 ON CC 39 LT | DRIVE TRIP | RESET | 17:05:00 19:10:00 | 17:15:00 19:20:00 | |
| 7 | CHP | S2 ON CC 36 | OLR ACTED | RESET | 20:55:00 | 21:05:00 | |