



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 6A	CD OLR ACTED	RESET	05:10:00	05:20:00	
2	OHP	CO16	OLR ACTED	RESET	00:20:00 01:00:00 01:40:00	00:30:00 01:10:00 01:50:00	
3	OHP	BRC ON CO 32	LT PCRD FWD CONTACTOR NC BLOCK PROBLEM	BLOCK BYPASSED	23:45:00	00:15:00	
4	CHP	CC 107	OLR ACTED	RESET	00:30:00	00:40:00	
5	CHP	SCR 1 ON CC 36	LUFF OLR ACTED	RESET	05:00:00	05:15:00	
6	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	00:00:00	05:30:00	
7	CHP	CC 131	OLR ACTED	RESET	04:30:00 05:30:00	04:35:00 05:35:00	
8	WT	OP5, 6 NOT MOVING	LC-2A INCOMER TRIPPED	RESET	02:00:00	02:15:00	
9	WT	OT2	PGF1 FAULT	RESET	03:50:00	04:00:00	
10	WT	OT4	D2 TRIPPED ON PGF4	RESET	05:00:00	05:15:00	