



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 28	pump not working, control fuse blown in spider cjb and in PLC panel	oil level sensor wire direct termination done in spider cjb	16:00:00	17:00:00	
2	OHP	TBS on CO 20	smoke observed near LT motor	brake problem, informed mechanical	19:20:00	19:30:00	
3	OHP	WOBR on co 25	slewing not working, m1 olr acted	reset	21:00:00	21:15:00	
4	OHP	CO 4A	p/c and emergency not healthy, fuse blown in cjb	fuse replaced	15:30:00	15:45:00	
5	CHP	CC 51	mpd acted 16 times	reset	15:00:00	15:05:00	
6	CHP	CC 51	motor tripped 3 times	reset	15:30:00	15:35:00	
7	CHP	CC 114	motor tripped 3 times	reset	17:30:00	17:35:00	
8	CHP	CC 34 SCR1	luff not working, limit acted	limit released	18:10:00	18:20:00	
9	WT	ot 2	d2 tripped in pgf1 fault	reset	19:36:00 21:20:00	19:41:00 21:25:00	