



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO67	olr acted	Reset done	00:10:00 22:55:00	00:15:00 23:05:00	
2	OHP	CO15	olr acted	Reset done	03:45:00	03:55:00	
3	OHP	CO84	olr acted	Reset done	03:45:00	04:05:00	
4	OHP	CO27A	BRS bypassed as per operational request	Bypassed	03:30:00	03:40:00	
5	OHP	CO34A	ZSS acting found probe damaged	Probe replaced	03:00:00	03:20:00	
6	OHP	CO29	TIS ZSS acting frequently due to belt slippage	informed to operation and mechanical they adjusted	03:45:00 05:15:00	03:50:00 05:45:00	
7	OHP	CO18	ZSS cage not rotating found module down side TB 's side damged and earth fault occurred fuse blown out	TB's directed and fuse replaced then ok	04:50:00	05:15:00	
8	OHP	CO26	Mechanical BRS acted	Reset done	05:15:00	05:30:00	
9	OHP	BF2A	ZSS acted found ZSS probe damaged	Work under	05:30:00	05:30:00	
10	CHP	CC51	MPD tripped stopped the feeding conveyor % times	Reset done	23:20:00	23:25:00	12.05am to 12.10am:01.05am to 01.10am :01.0am to 01.25am and 01.35am to 01.40am
11	CHP	CC19	olr acted 2 times	Reset done	04:15:00	04:25:00	04.27am to 4.30am



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Shift: C

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC103 TT	Position on CC105 bit missing	Bypassed in IO rake	03:45:00	04:05:00	
13	CHP	CC103 drive end and TT	chute sensors bypassed	As rain drops falling in sensor	03:40:00	04:00:00	
14	CHP	Cc26	Drive end chute sensor acted	Sensor cleaned and given clearance	03:00:00	03:10:00	again acted bypassed in module may normalise 04.05am to 4.10am
15	CHP	CC22	Chute sensor acted	Cleaned then ok	04:10:00	04:15:00	
16	CHP	CC37	LT not working found MPCB 3,5 and 6 tripped due to track jamming	Informed to operation	23:42:00	00:00:00	03.25am to 0.45am
17	CHP	CC44	olr tripped	Reset done	01:45:00	01:55:00	
18	CHP	SCR3 on CC40	LT OT acted	Released then ok	03:30:00 04:50:00	03:40:00 05:00:00	
19	CHP	CC125	BRS bypassed as per operational request inio rake	Bypassed	04:30:00	04:40:00	
20	CHP	CC112	Drive end side chute sensor acting frequently	Bypassed	04:30:00	04:40:00	
21	CHP	CC103,CC105	After running found control MCB tripped in panel	work under progress	06:00:00	06:00:00	
22	WT	OP3	Not moving Breaker tripped	Reset and made on	00:50:00	01:05:00	
23	WT	CC2	olr acted	reset done	00:45:00	00:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
24	WT	OP3	breaker tripped found at column no 11 to Column 12 area bottom pad fallen	Adjusted and damaged C clamp replaced then ok	03:00:00	03:40:00	
25	WT	OT3	not rotating	mechanical and electrical dept under progress	05:00:00	06:00:00	