



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 33M	LT not working,PCRD OT acted	OT released	01:30:00	01:45:00	
2	OHP	CO 67	OLR acted	reset	02:15:00	02:25:00	
3	OHP	BRC on CO 31	B/C not running, E Stop acted	EStop released	23:30:00	23:45:00	
4	CHP	CC 39 SCR 6	LT not working,M2 mpcb tripped	made it on	23:30:00	23:35:00	
5	CHP	cc 39 scr6	LT not working,M3 mpcb tripped	made it on	03:10:00	03:20:00	
6	CHP	CC 43	olr acted	reset	01:00:00	01:05:00	
7	CHP	CC 51	mpd acted	reset	00:38:00	00:44:00	4 times
8	CHP	CC 54	olr acted	reset	23:00:00	23:05:00	4 times