



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/06/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-30 BRC	LT NOT WORKING	DRIVE TRIPPED IN OL ... RESET DONE	08:00:00	08:20:00	
2	OHP	CO-35	OLR ACTED	RESET DONE	11:35:00	11:40:00	
3	OHP	CO-30 BRC	BC OLR ACTED	RESET DONE	12:40:00	12:50:00	
4	OHP	RSCO-10A	C/D AND B/D BOTH ARE IN TRIPPED CONDITION	RESET DONE AND TESTED	11:10:00	11:30:00	
5	OHP	CO-27A	OPR REQUEST TO KEEP BRS IN CKT	KEPT IN CKT	09:00:00	09:10:00	
6	OHP	CO-12	ZSS BYPASS REQ FROM OPERATION	BYPASSED	08:15:00	08:27:00	AGAIN KEPT IN CKT
7	OHP	CO-66	BRS BYPASS REQ FROM OPR	BYPASSED	09:00:00	09:10:00	KEPT IN CKT
8	OHP	CO-24 TBS	TRANSFORMER PROBLEM FROM C SHIFT	TRANSFORMER CHANGED BY G SHIFT ... TESTING GOING ON	06:00:00	14:00:00	
9	CHP	CC-33 SCR-4	LUFF NOT WORKING	WRONG COMPLAINT (PUMP WAS NOT ON)	06:35:00	06:45:00	
10	CHP	CC-32 SCR-5	SLEW NOT WORKING	WRONG COMPLAINT	07:34:00	07:45:00	
11	CHP	CC-126	CHUT JAM .... CJD WAS IN BYPASS IN IO RACK	KEPT IN CKT ... CJD PROBLEM RECTIFIED	09:10:00	09:45:00	
12	CHP	CC-40 SCR-6	ALL DRIVES STOPPED WORKING IN RUNNING	ACB OFF ... CONTROL WIRE LOOSE IN ACB PANEL ... FIXED PROPERLY AND ACB MADE ON	12:50:00	13:10:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/06/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-131	TRIPPED IN OLR	RESET DONE	09:15:00 13:12:00	09:20:00 13:18:00	
14	CHP	CC-54	TRIPPED IN OLR	RESET DONE	06:40:00	06:50:00	
15	CHP	CC-53	PULL CORD ACTED DUE TO MATERIAL AND CABLE DAMAGED	PULL CORD BYPASSED	08:05:00	08:20:00	