



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/10/2025

Shift: B

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|---|--|----------------------|----------------------|---------|
| 1 | OHP | DB1 | OLR ACTED | RESET | 15:05:00 | 15:15:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 20:20:00 21:35:00 | 20:30:00 21:45:00 | |
| 3 | OHP | CO 11 CD | OLR ACTED | RESET | 15:45:00 | 16:00:00 | |
| 4 | CHP | SCR 2 ON CC 34 | 30 DEGREE LIMIT ACTED | RESET | 18:55:00 | 19:10:00 | |
| 5 | CHP | SCR 7 ON CC 37 | BREAK FAIL ALARM ACTED | RESET | 21:00:00 | 21:15:00 | |
| 6 | CHP | CC 125 | OLR ACTED | RESET | 15:45:00 | 15:50:00 | |
| 7 | CHP | CC 102 | BRS ACTING FREQUENTLY DUE TO LOOSE CONNECTION IN MODULE | TIGHTENED THEN OK | 20:45:00 | 21:00:00 | |
| 8 | CHP | CC 51 | FEEDING CONVEYOR MPD ACTED | RESET | 15:00:00 | 22:00:00 | 5 TIMES |
| 9 | WT | OT1 | PGF1 DRIVE FAULT | RESET | 19:30:00 | 19:35:00 | |
| 10 | WT | CP1 NOT MOVING | MAIN CONTACTOR OFF | MADE IT ON | 19:15:00 | 19:20:00 | |
| 11 | WT | OT4 | INITIAL INDICATION NOT COMING | SENSOR CLEANED THEN OK | 20:30:00 | 20:35:00 | |
| 12 | IOSA | WBR L and T B/C | DOWN CJD SENSOR PROBLEM | BYPASSED AND INFORMED TO INSTRUMENTATION | 17:50:00 | 18:05:00 | |