



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	om 15 and crmp stream drives red.	1-14 LC 8 .i/c - tripped on earth fault	i/c -1 made on then given clearence.	11:00:00	11:15:00	load on i/c -1
2	OHP	co 19	stop pb acted/stuckup	released.	09:00:00	09:15:00	
3	OHP	co 50	tripped on olr	reset	06:45:00	06:55:00	
4	OHP	co 29	tripped on olr	reset	07:25:00	07:30:00	
5	OHP	co 77	tripped on olr	reset .	08:50:00	08:55:00	
6	OHP	co 3a	zss acting /zss jumping due no return idler near zss	inform to ope. and mech.	09:00:00	09:10:00	
7	OHP	brc on co 31	CT not taking place	drive tripped on olr.	09:40:00	09:50:00	
8	OHP	brc on co 31	CT not taking place	cabin side guide fallen.inform to ope. and mech	10:00:00	10:10:00	
9	OHP	wobr on co 6a	no drives running/auxilary power not making on	110v ac control supply temporary provided for plc.then given clearence	06:00:00	08:00:00	
10	CHP	scr 9 on 104	b w not running /oil level low	inform to operation and mech.	07:45:00	08:00:00	
11	CHP	scr 7 on cc37	no power from Cshift/ht fuse blown and R phase got earth fault .b and y phase getting 50 mega omhs	R PHASE AND EARTH CORE INTERCHANGED THEN TESTED OK	07:45:00	08:00:00	one ht fuse replaced.
12	CHP	CC223	NOT RUNNING FROM C SHIFT/.BRAKE FEED BACK NOT GETTING	brake feed back bypassed and brake loosen then given clearence.	06:00:00	09:00:00	
13	CHP	scr 6 on cc38	slew not taking place/limit acted due to jamming	jamming material clear.then ok	08:45:00	09:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	scr 2 on cc 40	ope.required lt limit bypass	end limit bypassed.	10:50:00	11:00:00	lt end limit kept in ckt at 1.30pm
15	CHP	cc 125	tripped on olr	reset done	09:44:00	09:50:00	
16	CHP	cc54	tripped on olr	reset	07:15:00	12:30:00	8 times due more material
17	CHP	cc 130	zss acting due more material on conv.	inform ope. to clear the material	11:00:00	11:10:00	