



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	not healthy,OLr acted,DMPR trips	reset	07:00:00	07:10:00	
2	OHP	RSCO 6A(c)	olr acted,track jamming	reset	08:00:00	08:15:00	
3	OHP	CO 48	OLR acted	reset	08:20:00	08:25:00	
4	CHP	CC 51	MPD trips,stop feeding conveyor	reset	07:00:00	07:05:00	4 times
5	CHP	CC 29 TT on 31	bit missing ,cable loose in I/O rack	tightened	11:30:00	11:35:00	
6	CHP	CC 201 ,202,203	OLR acted	reset	08:00:00	08:10:00	
7	CHP	CC 49	not healthy,BRS acted	reset	12:35:00	12:48:00	
8	CHP	CC 104 SCR9	cjd acted	wrong complaint	10:40:00	10:45:00	
9	WT	OT4	D 1 tripped in PGF1 fault	reset	07:40:00	07:45:00	
10	WT	CP 1	no movement,no power,ACB tripped	ACB made on,pad ok	13:00:00	13:10:00	