



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 05/12/2025

Area: CHP

| Equipment                  | Job   |
|----------------------------|---|
| CC-219                     | cc-222,223 beltscale tph overload interlock provided  |
| LIGHTING                   | RG-floor lighting circuit rectification done. ISB level lighting improved and CM-28 front side light arranged |
| CC-201,222,223 BELT SCALES | cleaning done   |
| LIGHTING                   | LC-4,5 front side door lighting arranged  |
| SCR-6,7                    | Instrumentation field switches ppm done   |
| LC-5 OF COB-5 STREAM       | UPS-I/C-1 from IMCC-9F-2 incoming supply changed to PMCC-5F-E feeder  |
| CC-112,SCR-8               | Running inspection done   |
| STK-2                      | motors ppm done   |
| CC-39,201,202,203          | ppm work done   |