



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/04/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	TRIPPED ON OLR	RESET DONE	22:25:00 23:30:00	22:30:00 23:40:00	
2	OHP	CO-8A BRC	CT NOT WORKING	DRIVE TRIPPED ON OL ... RESET DONE	00:10:00	00:30:00	
3	CHP	CC-34 SCR-2	SLEW NOT WORKING	OPERATOR DOING SLEW WITH LUFFING EXPLAINED	02:50:00	03:05:00	
4	CHP	CC-40 SCR-6	SLEW NOT WORKING	MATERIAL JAMMING ... INFORMED OPERATION FOR CLEANING	04:00:00	04:20:00	
5	CHP	CC-52	STOPPED ON ZSS	DUE TO MATERIAL OVERLOAD	01:35:00	01:40:00	
6	CHP	CC 113	STOPPING ON CC-52 OVERLOAD	CC-52 OVERLOAD BIT IS SHOWING HING EVEN WHEN CC-52 IN OFF CONDITION ... BIT REMOVED IN IO RACK	00:30:00	00:40:00	
7	CHP	CC-53	STOPPED ON BELT SWAY	ALL SWITCHES ARE OK... AND NO OFF-CENTERING BYPASSED IN IO RACK	00:20:00	00:35:00	
8	CHP	CC-114	TRIPPED ON OLR	RESET DONE	05:45:00	05:55:00	
9	CHP	CC-58	TRIPPED ON OLR	RESET DONE	22:30:00	22:50:00	
10	CHP	CC-117	TRIPPED ON OLR	RESET DONE	04:05:00	04:25:00	
11	CHP	CC-51	STOPPED ON ZSS	BELT LOOSE INFORMED MECHANICAL AND OPERATION	02:30:00	02:45:00	
12	WT	OT-5	TOP CLAMP NOT CLOSING COMPLETELY IN ON TIME	VERTICAL PRESSER SETTING CHANGED FROM 38 TO 40	22:45:00	23:00:00	