



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2025

Shift: B

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 13	OLR acted	reset done	17:55:00	18:05:00	
2	OHP	CO 29	OLR acted	reset done	17:45:00	17:50:00	
3	CHP	CC 203	OLR acted	reset	14:10:00	14:20:00	
4	CHP	CC 201	BC stopping frequently	Checked ZSS , working well	15:25:00	15:50:00	
5	CHP	CC 105 , SCR 10	BC stopping frequently	ZSS cage stucked, made free	17:00:00	17:20:00	
6	CHP	CC 32, SCR 5	LT not working	Overtension acted , released	17:55:00	18:10:00	
7	CHP	CC 32 , CC 33	No power in machines	No power in IC , in LBDS feeder 25 tripped . Made on . Also 1 HT fuse blown in CC 33. Meggar done in CC 33, found okay and charged. Given clearance	19:45:00	21:50:00	
8	CHP	CC 131	Tripped on overload (2 times)	reset done	17:30:00	20:40:00	
9	CHP	CC 113 A	Tripped on overload	reset done	19:20:00	19:30:00	
10	WT	OT 3	D 1 tripped encoder fault	reset done	14:50:00	15:00:00	
11	WT	SCO 1A	Carriage drive tripped on overload	reset done	17:40:00	17:45:00	
12	WT	OT 4	Not moving , D -2 tripped on pgf 1 fault. Again D-1 and D-2 tripped on pgf-1 fault	reset done	18:00:00 20:50:00	18:05:00 21:00:00	
13	WT	CO 4	Pull chord acted	bypassed	20:00:00	20:15:00	informed to C shift