



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 25/08/2025

Area: CHP

Equipment	Job
CC 37	110 V SENSOR REPLACED AND BRS TAKEN IN CIRCUIT
CC 54	PC SWITCHES CHECKING DONE 2 SWITCHES REMOVED
SCR 8 ON CC 112	LOW ACC PR 1 KEPT IN CIRCUIT
R1 ON CC 33 INTERLOCK CAGE	BELT PIECE CANOPY FIXED
MACHINE INTER CHANGING DONE	S 2 TO CC 35 SCR1 TO CC 36
CC 49	MOTOR REPLACED
CC 40, 43, 48, 49	PPM DONE