



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/12/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	22:20:00	22:30:00	
2	OHP	CR-2A	Reported ZSS acted	Wrong complaint	23:30:00	23:40:00	
3	OHP	BRC on CO-32	No operation is taking place	ACB made on and tested okay	00:10:00	00:20:00	
4	OHP	CO-111	Reported tripped	OLR acted.Reset done	00:30:00	00:40:00	
5	OHP	CO-29	Reported tripped	OLR acted.Reset done	04:40:00	04:50:00	
6	OHP	WOBR on CO-26	Reported slewing not taking place	Drive tripped.Reset done	03:05:00	03:15:00	
7	OHP	TBS on CO-19	Left luff not taking place	Wrong complaint	03:50:00	04:00:00	
8	OHP	BRC on CO-32	B/W-2 not rotating	Wrong complaint	03:20:00	03:05:00	
9	CHP	CC-51	MPD acted	Feeding conveyor stopped.Reset done(7 times)	00:11:00	05:05:00	
10	CHP	CC-35 SCR-3	LT not taking place	Drive tripped.Reset done	00:15:00	00:30:00	
11	CHP	Cc 104 SCR-9	Slew not working	OIL cooler motor tripped.Reset done	02:50:00	03:05:00	
12	CHP	CC 117	Reported tripped	OLR acted.Reset done	05:35:00	05:50:00	
13	WT	OT-4	Drive tripped	Drive tripped on PGEF-1 fault.Reset done	22:40:00	22:45:00	
14	IOSA	BRC	Breaker tripped	CT emergency acted.ACAB made on and Ct local reverse movement done and tested okay(2 times)	03:10:00	04:50:00	