



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/12/2025

Area: WT

| Equipment  | Job  |
|------------|--|
| MIS        | Spare Break panels made ready in both LC 1 and LC 9                        |
| OT 3       | Break panel rectified ,2nos Diodes replaced and C2 cantactor 40 A replaced |
| LC 2B      | Space Heater Supply checked and found available in both T1 and T2          |
| LC 2A      | Supply provided for space heater with MCB control for T2                   |
| CP 1 and 4 | After rake, maintenance done   |
| OP 4 and 6 | After rake, maintenance done   |