



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 26/11/2025

Area: IOSA

Equipment	Job
OJH-4B	PPM DONE ON ELECTRICAL HOIST AT OC-7C TAILEND.
BLENDER RECLAIMER	BRIDGE CONVEYOR PULLCHORD BASE GOT DAMAGED. REPLACED THE SWITCH AND TRIAL RUN TAKEN.
OC-13A	PULL CHORD HARDWARE SIGNAL NOT COMING. CHECKED AND RECTIFIED AND SAME AND REMOVED BYPASS.
WOBR-LnT	MAINTENANCE DONE ON SLIPRING ASSEMBLY , TRANSFORMER HT AND LT SIDE TERMINATION.
OC-36A	LIGHTING DEFECTS RECTIFICATION IS IN PROGRESS. ONE LIGHT FITTING PROVIDED NEW HEAD END AREA.