



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment             | Problem                                       | Action                  | From     | To       | Remarks       |
|-------|------|-----------------------|---|-------------------------|----------|----------|---------------|
| 1     | OHP  | BRC on CO 33M         | LT not working,PCRD OT acted                  | released                | 08:30:00 | 08:40:00 | guide problem |
| 2     | OHP  | BRC on CO 28          | all drive not working,acb tripped             | ACB made on             | 11:55:00 | 12:05:00 |               |
| 3     | OHP  | wobr on co 29         | b/c not running                               | operator cabin reset    | 10:55:00 | 11:00:00 |               |
| 4     | OHP  | 1-28 HVMCC 4          | oc 9a,11a,3a no power,l/C 2 tripped in LBDS 8 | made it on by CRP       | 13:40:00 | 14:05:00 |               |
| 5     | CHP  | CC 28(B)              | olr acted                                     | reset                   | 10:40:00 | 10:47:00 |               |
| 6     | CHP  | CC 117                | olr acted                                     | reset                   | 08:35:00 | 08:50:00 |               |
| 7     | CHP  | CC 113A               | olr acted                                     | reset                   | 12:22:00 | 12:25:00 |               |
| 8     | WT   | CO 4(C)               | olr acted                                     | reset                   | 11:20:00 | 11:25:00 |               |
| 9     | IOSA | LBDS 2 6.6 KV hvmcc 5 | i/c 1 tripped                                 | made it on by CRP panel | 06:40:00 | 06:50:00 |               |