



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------|--------------------------------|--|----------------------|----------------------|----------|
| 1 | OHP | BRC ON CO 32 SLEW | 24 V COMMON HIGH LOOSE IN CJB2 | TIGHTENED | 23:30:00 | 00:00:00 | |
| 2 | OHP | WBR ON CO 26 | SLEW DRIVE TRIPPED | RESET | 02:45:00 | 03:00:00 | |
| 3 | OHP | TBS ON CO 22 | LT PCRD GOT STUCKED | AFTER MECH CLEARANCE PLACEMENT DONE | 00:30:00 | 00:50:00 | |
| 4 | OHP | CO 26 | OLR ACTED | RESET | 01:45:00 03:05:00 | 01:55:00 03:15:00 | |
| 5 | OHP | WBR ON CO 29 | B/W MPCB TRIPPED | MADE IT ON | 02:20:00 | 02:40:00 | |
| 6 | OHP | WBR ON CO 26 LT | MCCB OFF | MADE IT ON | 00:40:00 | 00:55:00 | |
| 7 | CHP | R1 ON CC 32 | B/W OLR ACTED | RESET | 22:50:00 | 23:05:00 | |
| 8 | CHP | SCR 7 ON CC 37 LT | DRIVE FAULT | RESET | 00:30:00 | 00:50:00 | |
| 9 | CHP | CC 125 | OLR ACTED | RESET | 04:55:00 | 05:00:00 | |
| 10 | CHP | CC 54 | OLR ACTED | RESET | 23:30:00 | 04:25:00 | 13 TIMES |
| 11 | CHP | CC 51 | FEEDING CONV MPD ACTED | RESET | 04:45:00 | 04:55:00 | |
| 12 | CHP | CC 117 | OLR ACTED | RESET | 03:25:00 | 03:45:00 | |
| 13 | CHP | SCR 5 ON CC 33 | LT DRIVE TRIPPED | MADE IT ON | 05:45:00 | 05:55:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---------------------------|--------|----------|----------|---------|
| 14 | WT | CO 3 | OLR ACTED DUE TO JAMMING | RESET | 03:10:00 | 03:30:00 | |
| 15 | WT | AF2 | DRIVE TRIPPED ON OVERLOAD | RESET | 01:05:00 | 01:10:00 | |