



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/07/2025

Area: WT

Equipment	Job
OT Complex	Lighting job done,2 nos 200W LED replaced
OP 3	Motor side ppm done
OP 4,6,7 and CP 1	After rake maintenance done
OT 5	All Clamp/De clamp Limits (8nos) maintenance done